

Addendum No. 2

Issued: May 14, 2025

Project Name: Council Rock School District
Churchville Elementary School Backflow Preventer Replacement
CHA Project No. 101395

Project Owner: Council Rock School District
30 North Chancellor Street
Newtown, PA 18940

Engineer: CHA Consulting
One East Broad St., Suite 310
Bethlehem, PA 18018

BID DUE DATE: THURSDAY, MAY 29, 2025, AT 1:00 P.M. (UPDATED)

*This Addendum forms a part of the Contract Documents and modifies the original Bidding Documents dated **April 2025**. This addendum must be acknowledged on the Bid Form in the space provided for this purpose. Failure to so acknowledge this addendum may subject the Bidder to disqualification.*

1.0 GENERAL INFORMATION:

1.1 **All BIDDERS be informed, the Bid Due Date is REVISED via this Addendum FROM: Tuesday, May 27, 2025, at 2:00 p.m. TO: Thursday, May 29, 2025, at 1:00 p.m.**

1.2 This Addendum consists of four (4) pages and includes the following attachments:

- 1 Page of Sign-in sheet from the Pre-Bid Meeting held on May 3, 2025.
- 1 Page of Revised and Reissued Drawing P2.1, "Partial Floor Plans".

2.0 CHANGES TO PREVIOUS ADDENDA:

2.1 None.

3.0 CHANGES TO THE BIDDING REQUIREMENTS, CONTRACT FORMS, & CONDITIONS OF THE CONTRACT:

3.1 None.

4.0 CHANGES TO THE SPECIFICATIONS:

4.1 None.

5.0 CHANGES TO THE DRAWINGS:

5.1 Drawing P2.1, “Partial Floor Plan”, refer **DELETE** the existing drawing and **REPLACE** with revised and reissued Drawing P2.1, “Partial Floor Plan” attached to this addendum.

6.0 BIDDERS QUESTIONS:

6.1 Question: Is a confined space permit required?

Response: A partial scope of work includes plumbing work beneath the mechanical room floor accessed via a manhole cover. Contractor to include and comply with confined space requirements, certifications, permits, etc. that may be required in the base bid.

NOTE:

- **ALL BIDDERS MUST indicate receipt of this Addendum on Page 1 of the Bid Form.**
- **No other acknowledgment is needed or requested to be returned as the receipt of Addenda is tracked through the Sharefile service Addenda are issued through.**

V:\Projects\BPA132\Proj1\006-299 - Schools\283 - Council Rock SD\101395 - Churchville ES Backflow Preventor Replacement\Addenda\Addenda No. 2\14.05.25_Addendum No. 2_101395_Draft.docx

