

COUNCIL ROCK SCHOOL DISTRICT
Administration & Business Office
30 North Chancellor Street
Newtown, PA 18940
215-944-1000

Addendum No. 1

TO: All Vendors
RE: Air Filters Bid No. 25-22
DATE: April 4, 2025

Notice to all Vendors submitting Bids in response to the Air Filters Bid No. 25-22. This addendum is to amend or clarify the request for bid dated March 21, 2025:

General Information:

1. Do you have an excel spreadsheet you'd like us to input our final bid on?
The excel spreadsheet is included. All cells expect for the "Price as Each" column. The spreadsheet will automatic calculate the "Extended Price." You may also hand enter the price if you wish.

Responses must be submitted in a sealed hard copy format only to Ashleigh Esteves, Purchasing Department, 30 N Chancellor Street, Newtown, PA 18940. Emailed bid submissions **WILL NOT be considered.**
2. Sol Feinstone Elementary: What MERV rating are these metal filters (MERV 13 or 15) and do they need a header?
24 x 24 x 12 Metal – **MERV 13, metal box filters**
12 x 24 x 12 Metal – **MERV 13, metal box filters**
20 x 20 x 12 Metal – **MERV 13, metal box filters**
16 x 20 x 12 Metal – **MERV 13, metal box filters**

See pictures below:



COUNCIL ROCK SCHOOL DISTRICT

Administration & Business Office

30 North Chancellor Street

Newtown, PA 18940

215-944-1000

3. Richboro Elementary: Does this filter require a header?
19.75 x 24.75 x 4 MERV 14 – No header is required.

4. Newtown Middle: Do these filters require a header?
12 x 24 x 4 MERV 13 – Yes, a header is required
20 x 20 x 4 MERV 13 – Yes, a header is required
20 x 24 x 4 MERV 13 – Yes, a header is required
24 x 24 x 4 MERV 13 – Yes, a header is required

END OF ADDENDUM