

Addendum No. 2

Issued: March 5, 2024

Project Name: Council Rock School District
Twining Ford Road Maintenance Buildings Envelope Restoration
DEI Project No. 283090

Project Owner: Council Rock School District
30 North Chancellor Street
Newtown, PA 18940

Engineer: D'Huy Engineering, Inc.
One East Broad St., Suite 310
Bethlehem, PA 18018

BID DUE DATE: Tuesday, March 19, 2024, at 2:00 p.m.

*This Addendum forms a part of the Contract Documents and modifies the original Bidding Documents dated **February 2024**. This addendum must be acknowledged on the Bid Form in the space provided for this purpose. Failure to so acknowledge this addendum may subject the Bidder to disqualification.*

1.0 GENERAL INFORMATION:

- 1.1 If you would like to schedule additional site visits through CRSD, please contact Jessica Binda-Rischow at 215-944-1015 or email at jbinda-rischow@crsd.org. Contractors are required to check in at the building's main office upon arrival at the site.
- 1.2 This addendum consists of 2 pages with no attachments.

2.0 CHANGES TO PREVIOUS ADDENDA:

- 2.1 None.

3.0 CHANGES TO THE BIDDING REQUIREMENTS, CONTRACT FORMS, & CONDITIONS OF THE CONTRACT:

- 3.1 None.

4.0 CHANGES TO THE SPECIFICATIONS:

- 4.1 None.

5.0 CHANGES TO THE DRAWINGS:

- 5.1 Drawing E7.1.2, “Details”, Detail 2 “The Generator Duct Bank”. **ADD** the following note: “(1) 1.5” C. for Low-Voltage wiring.”
- 5.2 Drawing E7.1, “Details”, in the “Disconnect Switch Schedule” **REPLACE** as follows: “Tag DS-1 with DS-C.”
- 5.3 Drawing E7.1, “Details”, in the “Transfer Switch Schedule” **CLARIFY as follows:** “Provide an integral Generator exerciser.”

6.0 BIDDERS QUESTIONS:

- 6.1 None.

NOTE:

- **ALL BIDDERS MUST** indicate receipt of this Addendum on Page 1 of the Bid Form.
- **No other acknowledgment** is needed or requested to be returned as the receipt of Addenda is tracked through the Sharefile service Addenda are issued through.

G:\Projects\006-299 - Schools\283 - Council Rock SD\283090 - TFR Maintenance Buildings Envelope Restoration\Addenda\Addendum No. 2\Addendum No. current_Draft.docx